

## DRAFT 4/26/06

Please note that the document provided below is in draft form only and is subject to any and all applicable disclaimers found on the Illinois EPA's "Privacy Policy and Disclaimers" webpage. The contents herein, may be changed during the course of the development of the described rulemaking proposal and will not be considered in "final" form until it is filed with the Illinois Pollution Control Board. Further, any reference to or use of the draft document below for any purpose other than as a basis for providing comments to the Illinois EPA, including the reference to or use of the draft documents as "final" documents or information, is prohibited.

### **Section 201.146 Exemptions from State Permit Requirements**

Construction or operating permits, pursuant to Sections 201.142, 201.143 and 201.144 of this Part, are not required for the classes of equipment and activities listed below in this Section. The permitting exemptions in this Section do not relieve the owner or operator of any source from any obligation to comply with any other applicable requirements, including the obligation to obtain a permit pursuant to Sections 9.1(d) and 39.5 of the Act, Sections 165, 173 and 502 of the Clean Air Act or any other applicable permit or registration requirements. . .

- i) Any stationary turbine or internal combustion engine with a rated power output of less than 1118 kW (1500 ~~bhp horsepower~~), except that a permit shall be required for the following:
  - 1) Any stationary gas turbine ~~engine~~ with a rated heat input at peak load of 10.7 gigajoules/hr (10 mmbtu/hr) or more that is constructed, reconstructed or modified after October 3, 1977 and that is subject to requirements of 40 CFR 60, Subpart GG; or
  - 2) Any internal combustion engine with a rating at equal to or greater than 500 bhp output that is subject to the control requirements of 35 Ill. Adm. Code Part 217.Subpart Q.

(Source: Amended at \_\_\_ Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)