

Suggested Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State, and is being accomplished through the cooperation of homeowners and residents.

Please read the following directions prior to collection of the sample.

1. Prior arrangements will be made with the customer to coordinate the sample collection event. Dates will be set for sample kit delivery and pick-up by water department staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap the sample is taken from and any taps adjacent or close to that tap. The water department recommends that either early mornings or evenings upon returning home are the best sampling times to collect the sample.
3. A kitchen or bathroom cold-water faucet is to be used for sampling. Be sure to use a faucet that has been in recent general use by your household. If you have a water softener on your kitchen tap, collect your sample from the bathroom tap that is not attached to a water softener, if possible. **Do not remove the aerator prior to sampling.** Place the opened sample bottle below the faucet and gently open the cold water tap. Fill the sample bottle to the line marked "1000-mL" and turn off the water.
DO NOT FLUSH ANY WATER FROM YOUR FAUCET PRIOR TO FILLING THE BOTTLE
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. ***IF ANY PLUMBING REPAIRS OR REPLACEMENT HAS BEEN DONE IN THE HOME SINCE THE PREVIOUS SAMPLING EVENT, NOTE THIS INFORMATION ON THE LABEL AS PROVIDED. ALSO IF YOUR SAMPLE WAS COLLECTED FROM A TAP WITH A WATER SOFTENER, NOTE THIS AS WELL.***
6. Place the sample kit outside of the residence in the location of the kit's delivery so that department staff may pick up the sample kit.
7. Results from this monitoring effort will be provided to participating customers when reports are generated for the State. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 10 working days from the time of sample collection).

Call _____ at _____ if you have any questions regarding these instructions.

TO BE COMPLETED BY RESIDENT		
Water was last used:	Time _____	Date _____
Sample was collected:	Time _____	Date _____
I have read the above directions and have taken a tap sample in accordance with these directions.		
Signature		Date