General NPDES Permit ILG64
PWS Facility Review Sheet

Reviewer: Jaime Rabins Date: December 14, 2006

Permit Number: ILG640078

Facility:	Illinois American Water Company Sterling Water Treatment Plant 2911 West Lefevre Sterling, Illinois 61081	Address:	Illinois American Water Company 100 North Water Works Drive P.O. Box 24040 Belleville, Illinois 62223-9040

County:	Whiteside

Existing Facility: ✓Yes, No, (If no, facility is not eligible for coverage under the general permit)

Existing Facility with New Outfall or Increased Loading

✓No, Yes, (If yes, anti-degradation review required)
Completion Date:

Outfalls:

Number	Existing? (y/n)	Receiving Stream	Latitude	Longitude	Gen. Use or Sec. Contact
001	Y	Elkhorn Creek	41˚ 48’ 23”	89˚ 43’ 54”	General Use

Wastestreams: Clarifier Sludge Blowdown and / or Particulate Filter Backwash
✓Iron Filter Backwash
Zeolite Softener Wastewater

Is Wastewater Chlorinated ✓Yes Applicable Permit Paragraphs: ✓A. ✓B. C. ✓D.
No

Raw Water Source: ✓Groundwater
Surface Water

Is Arsenic Present in Wastewater: ✓No
Yes, Concentration

Is Radium Present in Wastewater: ✓No
Yes, Concentration