General NPDES Permit ILG64
PWS Facility Review Sheet

Reviewer: Jaime Rabins Date: December 12, 2006

Permit Number: ILG640175

Facility:	Village of Onarga – WTP Chestnut & Wilson Streets Onarga, Illinois 60955	Address:	Village of Onarga 111 North Chestnut Street Onarga, Illinois 60955

County:	Iroquois

Existing Facility: ✓Yes, No, (If no, facility is not eligible for coverage under the general permit)

Existing Facility with New Outfall or Increased Loading

✓No, Yes, (If yes, anti-degradation review required)
Completion Date:

Outfalls:

Number	Existing? (y/n)	Receiving Stream	Latitude	Longitude	Gen. Use or Sec. Contact
001	Y	Drainage Tile to Spring Creek	40˚ 42’ 56”	87˚ 57’ 50”	General Use

Wastestreams: Clarifier Sludge Blowdown and / or Particulate Filter Backwash
✓Iron Filter Backwash
Zeolite Softener Wastewater

Is Wastewater Chlorinated ✓Yes No Applicable Permit Paragraphs: ✓A. ✓B. C. ✓D.

Raw Water Source: ✓Groundwater
Surface Water

Is Arsenic Present in Wastewater: ✓No
Yes, Concentration

Is Radium Present in Wastewater: ✓No
Yes, Concentration