

# General NPDES Permit ILG64

## PWS Facility Review Sheet

Reviewer: Brian W. Cox

Date: December 22, 2009

Permit Number: ILG640259

Facility:	White Hall WTP East Lincoln Street 1.25 East of Route 67 White Hall, IL 62092	Permittee:	City of White Hall 116 East Sherman Street White Hall, IL 62092
-----------	---	------------	---

County:	Greene
---------	--------

Existing Facility: ☒ Yes, ☐ No, (If no, facility is not eligible for coverage under the general permit)

Existing Facility with New Outfall or Increased Loading

☒ No, ☐ Yes, (If yes, anti-degradation review required)  
Completion Date:

Outfalls:

Number	Existing? (y/n)	Receiving Stream	Latitude	Longitude	Gen. Use or Sec. Contact
001	Yes	Unnamed Tributary to Wolf Run Creek	39°26'29" N	90°22'34" W	General Use

Wastestreams: ☒ Clarifier Sludge Blowdown and / or Particulate Filter Backwash

☒ Iron Filter Backwash

☐ Zeolite Softener Wastewater

Is Wastewater Chlorinated ☒ Yes ☐ No      Applicable Permit Paragraphs: ☒ A. ☒ B.(1) ☐ C. ☒ D.

Raw Water Source: ☒ Groundwater  
☒ Surface Water

Average Flow: 0.032 MGD

Is Arsenic Present in Wastewater: ☒ No  
☐ Yes,

Concentration:

Is Radium Present in Wastewater: ☒ No  
☐ Yes,

Concentration: