

General NPDES Permit ILG64

PWS Facility Review Sheet

Reviewer: Brian W. Cox

Date: December 23, 2009

Permit Number: ILG640257

Facility:	Breese WTP, City of Old US 50 at Shoal Creek Breese, IL 62230	Permittee:	City of Breese 500 North First Street Breese, IL 62230
-----------	---	------------	--

County:	Clinton
---------	---------

Existing Facility: X Yes, No, (If no, facility is not eligible for coverage under the general permit)

Existing Facility with New Outfall or Increased Loading

 X No, Yes, (If yes, anti-degradation review required)
Completion Date:

Outfalls:

Number	Existing? (y/n)	Receiving Stream	Latitude	Longitude	Gen. Use or Sec. Contact
001	Yes	Unnamed Tributary to Shoal Creek	38°36'24.1" N	89°31'18.1" W	General Use

Wastestreams: X Clarifier Sludge Blowdown and / or Particulate Filter Backwash
 Iron Filter Backwash
 Zeolite Softener Wastewater

Is Wastewater Chlorinated X Yes No Applicable Permit Paragraphs: X A. B.(1 or 2) C. X D.

Raw Water Source: Groundwater Average Flow: 0.053 MGD
 X Surface Water DAF : 0.18 MGD

Is Arsenic Present in Wastewater: X No Yes, Concentration:

Is Radium Present in Wastewater: X No Yes, Concentration: