

# General NPDES Permit ILG64

## PWS Facility Review Sheet

Reviewer: Brian W. Cox

Date: December 22, 2009

Permit Number: ILG640120

Facility:	Village of Secor WTP S.E. Quadrant of Gilman & 3 <sup>rd</sup> Secor, Illinois 61771	Permittee:	Village of Secor P.O. Box 44 Secor, Illinois 61771
-----------	--	------------	--

County:	Woodford
---------	----------

Existing Facility: ☒ Yes, ☐ No, (If no, facility is not eligible for coverage under the general permit)

Existing Facility with New Outfall or Increased Loading

☒ No, ☐ Yes, (If yes, anti-degradation review required)  
Completion Date:

Outfalls:

Number	Existing? (y/n)	Receiving Stream	Latitude	Longitude	Gen. Use or Sec. Contact
001	Yes	Panther Creek	40°44'15" N	89°05'45" W	General Use

Wastestreams: ☒ Clarifier Sludge Blowdown and / or Particulate Filter Backwash  
☐ Iron Filter Backwash  
☐ Zeolite Softener Wastewater

Is Wastewater Chlorinated ☒ Yes ☐ No      Applicable Permit Paragraphs: ☒ A. ☐ B.(1 or 2) ☐ C. ☒ D.

Raw Water Source: ☒ Groundwater ☐ Surface Water      Average Flow: 0.003 MGD

Is Arsenic Present in Wastewater: ☒ No ☐ Yes,      Concentration:

Is Radium Present in Wastewater: ☒ No ☐ Yes,      Concentration: