

General NPDES Permit ILG64

PWS Facility Review Sheet

Reviewer: Brian W. Cox

Date: January 13, 2009

Permit Number: ILG640003

Facility:	Cullom WTP 105 Oak Street Cullom, Illinois 60929	Address:	Village of Cullom 105 Oak Street Cullom, Illinois 60929
-----------	--	----------	---

County:	Livingston
---------	------------

Existing Facility: ☒ Yes, ☐ No, (If no, facility is not eligible for coverage under the general permit)

Existing Facility with New Outfall or Increased Loading

☒ No, ☐ Yes, (If yes, anti-degradation review required)
Completion Date:

Outfalls:

Number	Existing? (y/n)	Receiving Stream	Latitude	Longitude	Gen. Use or Sec. Contact
001	Y	Unnamed Tributary to the North Fork of the Vermilion River	40°52'47" N	88°16'11" W	General Use

Wastestreams: ☐ Clarifier Sludge Blowdown and / or Particulate Filter Backwash
☒ Iron Filter Backwash
☐ Zeolite Softener Wastewater

Is Wastewater Chlorinated ☒ Yes ☐ No Applicable Permit Paragraphs: ☒ A. ☒ B.(1) ☐ C. ☒ D.

Raw Water Source: ☒ Groundwater ☐ Surface Water Average Flow: 0.019 MGD

Is Arsenic Present in Wastewater: ☒ No ☐ Yes, Concentration:

Is Radium Present in Wastewater: ☒ No ☐ Yes, Concentration: