

General NPDES Permit ILG640145
PWS Facility Review Sheet

Reviewer: **Shu-Mei Tsai**

Date: **Thursday, March 11, 2010**

Permit Number: **ILG640145**

Facility:	Avon Water Treatment Plant	Address:	Post Office Box 596 Avon, Illinois 61415
-----------	-----------------------------------	----------	---

County:	Fulton
---------	---------------

Existing Facility: **Yes,** No, (If no, facility is not eligible for coverage under the general permit)

Existing Facility with New Outfall or Increased Loading

No, Yes, (If yes, anti-degradation review required)
Completion Date:

Outfalls:

Number	Existing? (y/n)	Receiving Stream	Latitude	Longitude	Gen. Use or Sec. Contact
001	Yes	Cedar Creek	40° 40' 15"	90° 22' 30"	General Use

Wastestreams: Clarifier Sludge Blowdown and / or Particulate Filter Backwash
Iron Filter Backwash
Zeolite Softener Wastewater

Is Wastewater Chlorinated **Yes** Applicable Permit Paragraphs: **A. B. C. D.**
No

Raw Water Source: **Groundwater**
Surface Water

Is Arsenic Present in Wastewater: **No**
Yes, Concentration

Is Radium Present in Wastewater: **No**
Yes, Concentration