General NPDES Permit ILG64
PWS Facility Review Sheet

Reviewer: Leslie Lowry Date: 10-2-08

Permit Number: ILG640027

Facility:	Griggsville Water Treatment Plant Route 107, North of Griggsville Griggsville, IL 62340	Address:	City of Griggsville P.O. Box 272 Griggsville, IL 62340

County:	Pike

Existing Facility: X Yes, No, (If no, facility is not eligible for coverage under the general permit)

Existing Facility with New Outfall or Increased Loading

No, Yes, (If yes, anti-degradation review required)
Completion Date:

Outfalls:

Number	Existing? (y/n)	Receiving Stream	Latitude	Longitude	Gen. Use or Sec. Contact
001	Y	Unnamed Ditch Tributary to South Fork of McKee Creek	39º 44’ 45”	90º 43’ 20”	General Use

Wastestreams: Clarifier Sludge Blowdown and / or Particulate Filter Backwash
X Iron Filter Backwash
Zeolite Softener Wastewater

Is Wastewater Chlorinated X Yes Applicable Permit Paragraphs: A, B, and D
No

Raw Water Source: X Groundwater Average Flow: 0.025 MGD
Surface Water

Is Arsenic Present in Wastewater: X No
Yes, Concentration

Is Radium Present in Wastewater: X No
Yes, Concentration